



RLY #1	40 NC 41 NO 42 C	Relay may be programmed as fail safe to detect power failure Rating 2 A @ 250 VAC
RLY #2	43 NC 44 NO 45 C	
RLY #3	46 NC 47 NO 48 C	
RLY #4	49 NC 50 NO 51 C	
Digital Inputs	61 Digital Input #1 62 Digital Input #2 63 Digital Input #3 64 Digital Input #4 65 Common	To activate an input apply 5 - 24 VDC for logic '1', apply 0 VDC for logic '0'.